PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No: 792

DATE: 30-7-2026

It is certified that inspection team headed by Executive Engineer Rural drinking water and sanitation division Haveri inspected the **Roshni Central School, ViratNagar , Near APMC Hangal** and found that Roshni Central School, ViratNagar , Near APMC Hangal as safe drinking water facilities for the students and members of staff of the school and is maintaining the hygienic sanitation condition in the school building and the campus as per rooms prescribed by the central/state/U.T.gov.

The above is valid for one year

Signature with seal:

EXECUTIVE ENGINEER
Rural Drinking Water & Sanitation
Division, Haveri.

Executive Engineer

Rural drinking water & sanitation division Haveri.

Digitally signed by PHILOMENA NORONHA
Date: 2026.09.25 00:34:52 +05:30
Reason: reason
Location: location

Headmistress
Roshni Central School
Virat Nagar, Near A.P.M.C.
HANGAL-581104 Haveri Dist.

Scanned with OKEN Scanner

HAVERI DISTRICT WATER QUALITY TESTING LABORATORY,
RURAL DRINKING WATER AND SANITATION DEPARTMENT-HAVERI,
VIDYANAGAR OLD ZP COMPOUND,HAVERI, KARNATAKA, INDIA
e-mail: ee.rws.hvr @gmail.com /rdwsd.wqmsp.haverilab@gmail.com
Phone No:08375- 237129

District Name: Haveri

Laboratory Name: Division Laboratory

TEST REPORT

Address: Roshni Central School
Virat Nagar
Near APMC
Hangal

Taluk:Hangal
District:Haveri

Report date:30.07.2026
Report Number:28
Sample receipt date:28.07.2026
Sample code:HAN26JULDW28
Date of Sampling:28.07.2026
Analysis start date:28.07.2026
Analysis completion date:29.07.2026
Sample Collection method: Manual for Water Quality Analysis,RDWSD,GoK
Sample quantity: 1000 ml

Sample Particulars:Drinking Water

Sl. No	Test	Results	Acceptable Limit IS 10500:2012 RA 2023	Permissible Limit 10500:2012 RA 2023	Test Method
Description: Colourless Liquid					
1.	pH Value @25^{0}C	6.98	6.5-8.5	No Relaxation	IS 3025(Part 11):2022
2.	Specific Conductance µS/cm at @25^{0}C	193	-	-	IS 3025(Part 14):2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):2023
5.	Colour, Hazen	5	5	15	IS 3025 (Part-4):2021
6.	Turbidity,NTU	0.5	1	5	IS 3025 (Part 10):2023
7.	Total Dissolved Solids,mg/l @ 180^{0}C,mg/l	116	500	2000	IS 3025 (Part 16):2023
8.	Total Alkalinity as $CaCO_3$,mg/l	24.12	200	600	IS 3025 (Part 23):2023
9.	Total Hardness as $CaCO_3$,mg/l	76.83	200	600	IS 3025 (Part 21):2019
10.	Calcium as Ca,mg/l	17.80	75	200	IS 3025 (Part 40): 2024
11.	Magnesium as Mg,mg/l	7.85	30	100	IS 3025 (Part 46): 2023
12.	Chloride as Cl,mg/l	33.00	250	1000	IS 3025 (Part 32):2025
13.	Sulphate as SO_4,mg/l	8.19	200	400	IS 3025 (Part 24 Sec-1):2022
14.	Fluoride as F,mg/l	0.177	1	1.5	APHA 24rdEdition:4500F-D:2023
15.	Nitrate as NO_3,mg/l	2.44	45	No Relaxation	APHA 24rdEdition:4500NO_3-B:2023
16.	Iron as Fe,mg/l	0.102	1	No Relaxation	IS 3025 (Part 53):2024

Remark:The above tested parameters conforms that they are within the acceptable limit as per the specification of IS10500:2012 RA:2023

Verified by:
Junior Analyst:Bhagyashree N Bangigoudra

Authorized Signatory:
Technical Manager :Bhuvaneshwari.R.Patil

RDWSD/WQMSP/TeR/01

Headmistress
Roshni Central School
Virat Nagar, Near A.P.M.C.
HANGAL-581104 Haveri Dist.

- End of the report-

Scanned with OKEN Scanner